



202404030041

04/03/2024 01:07 PM Pages: 1 of 2 Fees: \$304.50
Skagit County Auditor

After Recording Return To:
Kelvin Beaton
PO Box 205
Burlington, WA 98233



Skagit County Public Health

Keith Higman, Director
Howard Leibrand, M.D., Health Officer

NOTIFICATION OF DRINKING WATER SYSTEM STATUS

This form must be recorded before final approval

DRINKING WATER SYSTEM NOTICE TO CURRENT AND FUTURE PROPERTY OWNERS

PROPERTY OWNER(S): KELVIN BEATON

ADDRESS: 7677 BLOSSOMBERRY LANE, SEDRO-WOOLLEY, WA 98284

PARCEL NUMBER: P128427

LEGAL DESCRIPTION (see Assessor description):

(1.0000 ac) BUILDING PORTION OF LOT 1, ALTERATION BLUNT SHORT CARD PL07-0919, RECORDED UNDER AF#202312200023, A REVISION OF SHORT PLAT#PL07-0919 AF#200908170131, LOCATED IN THE SW1/4 AND SE1/4, SECTION 7, TOWNSHIP 35 NORTH, RANGE 6 EAST, W.M.

THE FOLLOWING INFORMATION HAS BEEN DISCLOSED TO THE HOMEOWNER AS PER SKAGIT COUNTY CODE (SCC) Chapter 12.48 Rules and Regulations of the Skagit County Board of Health Governing Individual and Public Drinking Water Systems:

- This Status Report is binding on all my heirs and/or successors and agree to hold the County harmless from any and all claims, damages, costs or expenses that are incurred whether personal injury or property damage that are water quantity, water quality or a result of the use of this alternative source.
- Water systems with filed Status Reports will not be used as justification to create new lots. Land divisions required either drilled wells or connection to an approved public system.
- Future buyers should be aware that the drinking water source for this property is provided by rainwater catchment. Public Health considers rainwater catchment as a surface water source. This source requires continuous filtration and disinfection on all faucets to be considered sanitary. This system was engineered by NW Rain Solutions and provides 250 gallons per day plus auxiliary storage in the amount of 20,000 gallons. The final inspection and as-built documents will be/have been completed by a licensed engineer.
- Additional water for storage must be purchased from a public water system approved by the Washington Department of Health.
- I agree to abide by the operations and monitoring requirements submitted with the water source application documents and make monitoring information available to the Health Officer upon request.

Connection to a public water system, when available, is recommended by Public Health. I have read and fully understand the conditions contained within this notification.

DATED this 2 day of April, 2024.

Kelvin Beaton, Property Owner

State of Washington)
)ss.
County of Skagit)

Signed or attested before me on April 2, 2024 by Kelvin Beaton (property owner).

Seal/Stamp



Gratianne E Martin

Printed Name: Gratianne E Martin

Notary Public in and for the State of Washington

My commission expires: May 27th 2024

UNOFFICIAL DOCUMENT