



Skagit County Public Health
On Site Sewage Program
1800 Continental Place
Mount Vernon, WA 98273
Email: EH@co.skagit.wa.us Fax: 360-416-1501

For Office Use

ON SITE SEWAGE SYSTEM REPORT

Gravity HOMEOWNER INSPECTION FORM

Inspection Date:	Inspected by:	
Parcel Number:	Site Address:	City:
Owner Name:	Phone Number:	Email address:
Certification Location and Date: <i>Ex: Septics 201, 1/18/2018 WSU Research Station</i>		Required Photographs (*): <input type="checkbox"/> Open tank <input type="checkbox"/> Outlet baffle <input type="checkbox"/> D-Box

Septic Tank	Capacity(G):	Comments
Effluent level within operational limits *	<input type="checkbox"/> Yes <input type="checkbox"/> No (if no, explain)	
Effluent screen/filter in place and clean	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Required baffles in place & good condition *	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Component appears sound and watertight	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Compartment 1 - Scum accumulation (inches)		
Compartment 1 - Sludge accumulation (inches)		
Compartment 2 - Scum accumulation (inches)		
Compartment 2 - Sludge accumulation (inches)		
Pumping recommended?	<input type="checkbox"/> Yes <input type="checkbox"/> No	
<i>Pumping is not required, but recommended at times. Use the formula on the next page to answer this question</i>		
Drainfield		
Ponding present	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Distribution Box checked *	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
D-box outlets set to allow equal effluent distribution	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
General Site and System Conditions		
All components accessible for service	<input type="checkbox"/> Yes <input type="checkbox"/> No	
All required components inspected	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Surfacing effluent from any component	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Improper encroachment or settling	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Structures connected to system occupied	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Risers watertight and in good condition	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
As built available	<input type="checkbox"/> Yes <input type="checkbox"/> No	
Reserve area in tact	<input type="checkbox"/> Yes <input type="checkbox"/> No	



Skagit County Public Health
On Site Sewage Program
1800 Continental Place
Mount Vernon, WA 98273
Email: EH@co.skagit.wa.us Fax: 360-416-1501

For Office Use

Comments:

For questions, please contact us at the following: Samantha Russell srussell@co.skagit.wa.us Greg Geleynse gregg@co.skagit.wa.us Corrina Marote corrinam@co.skagit.wa.us

I certify that this inspection is for my single family residence, residential rental unit or accessory dwelling unit and I meet the other Skagit County Public Health requirements to perform this inspection, which may include a joint inspection with, or follow up by, an Environmental Health Specialist in the future per the Homeowner On-Site Sewage System Inspection Policy. **I have included the required photographs (*) of the following: 1. each open tank, 2. each outlet baffle 3. the distribution box (if present) (Required).**

Signature of Inspector: _____ Date: _____

Does my tank need pumping? Fill out this handy equation to decide. Fill this chart out starting in the top left corner, and finish each line like a math equation. *Pumping is recommended (not required) when the tank is 1/3 full of solid material. Operational Depth is the depth of the interior of the septic tank. Average operational depth is 48-52" thus pumping is recommended at 18" solid material accumulation, or when solids are within 3" of either side of the outlet baffle.*

1 st compartment scum	+	1 st compartment sludge	÷	Average solids depth	=
----------------------------------	---	------------------------------------	---	----------------------	---

Total Solids greater than 1/3 (0.33)? Contact a licensed pumper.