


Cutting, Notching, and Boring of Studs


IBC 2308.9 Wall Framing in Skagit County



2308.9.10 Cutting and notching. In exterior walls and bearing partitions, any wood stud is permitted to be cut or notched to a depth not exceeding 25 percent of its width. Cutting or notching of studs to a depth not greater than 40 percent of the width of the stud is permitted in nonbearing partitions supporting no loads other than the weight of the partition.

2308.9.11 Bored holes. A hole not greater in diameter than 40 percent of the stud width is permitted to be bored in any wood stud. Bored holes not greater than 60 percent of the width of the stud are permitted in nonbearing partitions or in any wall where each bored stud is doubled, provided not more than two such successive doubled studs are so bored.

In no case shall the edge of the bored hole be nearer than 5/8 inch (16mm) to the edge of the stud. Bored holes shall not be located at the same section of stud as a cut or notch.



For more information contact:

Skagit County Planning & Development Services
 1800 Continental Place · Mount Vernon, WA 98273
 (360) 336-9410 · Fax (360) 336-9416 · web site address: www.skagitcounty.net

