



NOTES:

- EXPANSION JOINT MATERIAL TO BE 3/8" THICK PREMOLDED JOINT FILLER FULL THICKNESS OF CONCRETE SPACING.
- FORM AND SUBGRADE INSPECTION REQUIRED BEFORE POURING CONCRETE.

PCCCurb&Gutter.doc



SKAGIT COUNTY
DEPARTMENT OF
PUBLIC WORKS

REVISIONS	DATE

ROADWAY
STANDARDS

CEMENT CONCRETE
CURB AND GUTTER

FIGURE C - 6

6/26/200