



# SKAGIT COUNTY PUBLIC WORKS DEPARTMENT

1800 Continental Place, Mount Vernon, WA 98273-5625  
(360) 416-1400 FAX (360) 416-1405

## MEMORANDUM

**DATE:** June 7, 2022  
**TO:** Prospective Bidders & Plan Holders  
**FROM:** Joel Shroyer, Project Manager  
**SUBJECT:** Prairie Road Guidance Improvements, Q&A

---

The intent of this memo is to provide all prospective bidders with a compilation of questions asked to ensure an equal bidding opportunity.

### Informal Questions:

- I am wondering if I am missing any specs? I am not locating section 8 in the Contract Provisions.
  - *Division 8 is not included in the Contract Provisions because there are no deviations from the Standard Specifications with regards to Miscellaneous Construction.*
- I do not see a line item for surveying, how is survey layout to be addressed?
  - *There is no bid item for surveying. With regards to Profiled Paint, the field inspector will verify location per construction note in plans. With regards to Flexible Guide Posts, the provided curve radii on the plans and the referenced WSDOT Standard Plan provides adequate information to properly layout guide post locations.*