

AMENDMENT NUMBER 1 TO THE BID DOCUMENTSAmendment Date: **May 16, 2023****SKAGIT COUNTY FIRE ALARMS REPLACEMENT**

A. This Amendment shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents, this Amendment shall govern and take precedence. **BIDDERS MUST SIGN THE AMENDMENT AND SUBMIT IT WITH THEIR BIDS.**

B. Bidders are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Amendment. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

Except as described below, the original bid document remains unchanged. The bid documents are modified and/or clarified, as follows:

1. Panel & Electrical Schedule Specifications:

- a. Courthouse: All electrical is available in the room with the fire panel, the panel is fed off the X-1 emergency panel - via Panel X, which is conveniently adjacent to the existing fire panel.
- b. Administration Building: All electrical is fed from our electrical room in the first-floor mechanical room (HVAC room). This panel is additionally supplied by the X-1 emergency panel.
- c. Panel Schedules: Reference included Panel X and Panel X-1 schedules.

2. Essential fire alarm panel replacements must remain on same electrical circuits or (similar) because of backup power supported by on-site emergency generator.

If you need additional details or instructions, please contact Eric Peterson at epeterson@co.skagit.wa.us or phone 360-416-1176.

BIDDER MUST ACKNOWLEDGE THIS AMENDMENT BY SIGNING BELOW AND ATTACHING THE SIGNED AMENDMENT TO THE BID FORM:

Company Name _____

Contact Person _____

Signature _____

Date _____

Square D Type NQOBBack fed Main Breaker
60A 120/208 (Emergency)
(Fed from Panel X1 in Admin)
 Courthouse Electrical Room

Square D Type NQOBBack fed Main Breaker
60A 120/208 (Emergency)
(Fed from Panel X1 in Admin)
 Courthouse Electrical Room

[illegible]

m.c.s.

1St Flr Admin Electrical Rm #130

[illegible]