

**AMENDMENT NUMBER 2 TO THE BID DOCUMENTS**Amendment Date: **July 7, 2025****SKAGIT COUNTY COMMUNITY JUSTICE CENTER PHYSICAL BARRIERS PROJECT**

**A. This Amendment shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents, this Amendment shall govern and take precedence.**

Except as described below, the original bid document remains unchanged. The bid documents are modified and/or clarified, as follows:

1. **Fencing Specifications.** Information regarding the infill panel for the physical barriers being requested can be found on Sheet A11.1 within the Permit Set documents
2. **Background Checks.** Will be conducted by County Sheriff Department with a requirement for Contractor to provide full name, date of birth, and social security number for all employees and subcontractors. Additionally, email address for each contractor will need to be provided for receipt of link to online Security Awareness Training that will take about 30 minutes.
3. **What is the preferred 1/4 rivet to be used throughout the panels?** Rivets are a Delegated Design item by Coiled Weave Manufacturer. Refer S0.1 (SUBMITTALS) and 5A/S1.0.
4. **Section 051200, 1.7 Quality Assurance B.- Says the installer has to be AISC certified Erector. Is there an alternative to this statement?** AISC Erector Certification may be waived where all field welds performed by WABO certified welders. Field Special Inspection is required in either instance per S0.2.
5. **What type of material are you wanting the rivets for the mesh to be?** Refer to Response for Question 3.
6. **Are we welding the angle for the bottom of the new system directly to the top of the existing guardrail?** Confirmed – weld new HSS and angles to existing HSS per 2A/S2.0 and 2C/S2.0.
7. **What are the fire watch rules that the contractor must adhere to? Are we able to put up the protective fabric over the overwatch window for eye protection?** No response – Contractor Means and Methods.
8. **Availability of Material Dimensions:** For ease of procurement, an HSS 5x2-1/2x1/4 section can be used in lieu of HSS 4x2-1/2x3/8. Maintain all clearances and follow details as indicated in drawings.